

RECOMMENDED DOOR HARDWARE (FURNISHED BY GENERAL CONTRACTOR)

<u>Hinges</u>: (3) 4" \times 4" full mortise hinges [at least (1) hinge is to be spring hinge].

Recommended Source: Standard Hinge: Hager Co. part# BB1279
Spring Hinge: Bommer Ind. part# LB4310C-400

Door Handles: Flush or recessed door pulls are required on the interior (shaft side) of doors. Hardware is not to project more than 1" from face of door. Inactive/dummy door handle, knob, or lever required on exterior (house side) of doors.

Recommended Source (shaft side): Baldwin #0395 ring pull or similar

HEADER

SHEETROCK

- OPTIONAL INSIDE MOLDING/CASING (1/4" THICK MAX.)

OUTER DOOR JAMB

Latch: Adjustable roller latch with 2 3/4" \times 1 1/8" T-strike.


DOOR CASING -(TYPICAL)

3/4" THICK DOOR

(BY G.C.) (MUMINIM)

CONTRACTOR NOTES:

- KILN DRIED SOLID CORE WOOD DOORS/FRAMES TO BE PROVIDED AND INSTALLED BY THE GENERAL CONTRACTOR. DOOR CLOSERS OR SPRING LOADED HINGES ARE REQUIRED
- 2. CLEARANCE BETWEEN THE HOISTWAY DOOR AND SILL MUST BE HELD AT 3/4" PER ASME A17.1-2016. NO DEVIATIONS. SEE DETAILS.
- ALL DOOR FRAMES MUST BE SET SQUARE AND PLUMB. AVOID DOORS DRAGGING AGAINST FRAME.
- 4. DOORS/FRAMES MUST BE SET PERFECTLY PLUMB AND INLINE WITH ONE ANOTHER FROM FLOOR TO FLOOR. PLUMB LINES MUST BE USED WHEN SETTING DOORS/FRAMES.
- HOISTWAY DOORS ARE TO BE MARKED OUT BY ELEVATOR CONTRACTOR THEN NOTCHED/CUT-OUT BY GENERAL CONTRACTOR TO ACCEPT ELEVATOR DOOR LOCK FURNISHED BY ELEVATOR CONTRACTOR.



DOOR OPENING HEIGHT

FIN. FLOOR -

INACTIVE/DUMMY DOOR HANDLE, -KNOB, OR LEVER REQUIRED ON EXTERIOR (HOUSE) SIDE OF DOORS. (BY GENERAL CONTRACTOR)

ROPED HYDRAULIC

manufacturing company, inc.

RESIDENTIAL ELEVATOR